

Report No.: TP13060147-ETS
Date: September 18, 2013
Page 1 of 5

TEST REPORT

Applicant: Ablerex Electronics Co., Ltd.
1F, No. 3, Lane 7, Paokao Rd., Hsintien 23144, Taipei Hsien, Taiwan.

Product: Power inverter for PV

Model: ES 12000

Rating: Input: Max. 1000Vdc, voltage range 300-1000Vdc,
MPPT range 370-850Vdc, max. 2 x 14.3A
Output: 3/N/PE, 230/400Vac, 50/60Hz, max. 3 x 17.39A, 12kW

Sample Description: The product covered by this report is PV inverter.


Testing Standard: According to IEEE std 519-1992

Date of Receipt of Test: September 18, 2013

Date of Performance of Test: July 15, 2013 ~ July 16, 2013

Conclusion: From the results of our testing on the submitted sample(s), we are of the opinion that the submitted sample(s) **COMPLY WITH** the above testing specification.

Prepared by:


Nicky Huang
Project Engineer

Reviewed by:


Tin Lin
Supervisor

- 1) The testing results relate only to the items tested.
- 2) The test report shall not be reproduced except in full, without written approval of the laboratory.
- 3) This test report only allows to be revised within three years from its original issued date unless a further updating to the standard or requirement is noticed.
- 4) This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.
- 5) The test report only allows to be revised within three years from its original issued date unless further standard or the requirement was noticed.
- 6) When determining the test conclusion, the Measurement Uncertainty of test has been considered.

Harmonics test for Inverters

Results: (U Phase)

| Load current (A) | | 17.3A×3 | | EUT rated current (A) | | 17.3A×3 | | DC input | | 740 | Vdc |
|------------------|--------------|--------------|--------------|-----------------------|--------------|--------------|--------------|--------------|--------------|--------------|-----|
| | | | | | | | | AC output | | 230 Vac | |
| Harm. order | | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | |
| Current (%) | | 0.848 | 0.251 | 0.203 | 0.975 | 0.220 | 1.764 | 0.146 | 0.117 | 0.118 | |
| Limit (%) | | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 | |
| <hr/> | | | | | | | | | | | |
| Harm. order | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | |
| Current (%) | 0.993 | 0.134 | 0.692 | 0.096 | 0.088 | 0.067 | 0.430 | 0.074 | 0.275 | 0.063 | |
| Limit (%) | 2.000 | 0.500 | 2.000 | 0.500 | 2.000 | 0.500 | 1.500 | 0.375 | 1.500 | 0.375 | |
| <hr/> | | | | | | | | | | | |
| Harm. order | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | |
| Current (%) | 0.063 | 0.036 | 0.192 | 0.035 | 0.129 | 0.041 | 0.037 | 0.019 | 0.092 | 0.022 | |
| Limit (%) | 1.500 | 0.375 | 0.600 | 0.150 | 0.600 | 0.150 | 0.600 | 0.150 | 0.600 | 0.150 | |
| <hr/> | | | | | | | | | | | |
| Harm. order | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | |
| Current (%) | 0.057 | 0.024 | 0.026 | 0.013 | 0.039 | 0.014 | 0.028 | 0.013 | 0.012 | 0.011 | |
| Limit (%) | 0.600 | 0.150 | 0.600 | 0.150 | 0.300 | 0.075 | 0.300 | 0.075 | 0.300 | 0.075 | |
| TRD (%) | 2.492 | | | | | | | | | | |
| Limit (%) | 5 | | | | | | | | | | |

Harmonics test for Inverters

Results: (V Phase)

| Load current (A) | | 17.3A×3 | | EUT rated current (A) | | 17.3A×3 | | DC input | | 740 Vdc |
|------------------|--------------|--------------|--------------|-----------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| | | | | | | | | AC output | | 230 Vac |
| Harm. order h | | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| Current (%) | | 0.512 | 0.102 | 0.183 | 0.904 | 0.173 | 1.763 | 0.143 | 0.111 | 0.133 |
| Limit (%) | | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 |
| <hr/> | | | | | | | | | | |
| Harm. order h | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 |
| Current (%) | 0.894 | 0.116 | 0.707 | 0.099 | 0.080 | 0.082 | 0.358 | 0.074 | 0.285 | 0.055 |
| Limit (%) | 2.000 | 0.500 | 2.000 | 0.500 | 2.000 | 0.500 | 1.500 | 0.375 | 1.500 | 0.375 |
| <hr/> | | | | | | | | | | |
| Harm. order h | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 |
| Current (%) | 0.050 | 0.049 | 0.147 | 0.045 | 0.128 | 0.038 | 0.028 | 0.025 | 0.070 | 0.022 |
| Limit (%) | 1.500 | 0.375 | 0.600 | 0.150 | 0.600 | 0.150 | 0.600 | 0.150 | 0.600 | 0.150 |
| <hr/> | | | | | | | | | | |
| Harm. order h | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 |
| Current (%) | 0.058 | 0.022 | 0.018 | 0.013 | 0.031 | 0.016 | 0.027 | 0.013 | 0.014 | 0.009 |
| Limit (%) | 0.600 | 0.150 | 0.600 | 0.150 | 0.300 | 0.075 | 0.300 | 0.075 | 0.300 | 0.075 |
| TRD (%) | 2.436 | | | | | | | | | |
| Limit (%) | 5 | | | | | | | | | |

Harmonics test for Inverters

Results: (W Phase)

| Load current (A) | | 17.3A×3 | | EUT rated current (A) | | 17.3A×3 | | DC input | | 740 Vdc |
|------------------|--------------|--------------|--------------|-----------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| | | | | | | | | AC output | | 230 Vac |
| Harm. order h | | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| Current (%) | | 0.680 | 0.177 | 0.193 | 0.939 | 0.196 | 1.763 | 0.145 | 0.114 | 0.126 |
| Limit (%) | | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 | 4.000 | 1.000 |
| <hr/> | | | | | | | | | | |
| Harm. order h | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 |
| Current (%) | 0.943 | 0.125 | 0.700 | 0.097 | 0.084 | 0.074 | 0.394 | 0.074 | 0.280 | 0.059 |
| Limit (%) | 2.000 | 0.500 | 2.000 | 0.500 | 2.000 | 0.500 | 1.500 | 0.375 | 1.500 | 0.375 |
| <hr/> | | | | | | | | | | |
| Harm. order h | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 |
| Current (%) | 0.056 | 0.042 | 0.170 | 0.040 | 0.128 | 0.039 | 0.033 | 0.022 | 0.081 | 0.022 |
| Limit (%) | 1.500 | 0.375 | 0.600 | 0.150 | 0.600 | 0.150 | 0.600 | 0.150 | 0.600 | 0.150 |
| <hr/> | | | | | | | | | | |
| Harm. order h | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 |
| Current (%) | 0.058 | 0.023 | 0.022 | 0.013 | 0.035 | 0.015 | 0.027 | 0.013 | 0.013 | 0.010 |
| Limit (%) | 0.600 | 0.150 | 0.600 | 0.150 | 0.300 | 0.075 | 0.300 | 0.075 | 0.300 | 0.075 |
| TRD (%) | 2.464 | | | | | | | | | |
| Limit (%) | 5 | | | | | | | | | |