



BUREAU  
VERITAS

**Test Report No.: PV200319E02**

**Client**

Name : ABLEREX ELECTRONICS CO., LTD.  
Address : 1F, No. 3, Lane 7, Paokao Rd., Hsintien 23144, New Taipei City, Taiwan

**Test Item :** Grid-tied photovoltaic inverter

**Identification :** ES3075KBN, ES3075KBS, ES3075KBI, ES3075KBA, ES3066KBN, ES3066KBS, ES3066KBI, ES3066KBA, ES3063KBN, ES3063KBS, ES3063KBI, ES3063KBA, ES3060KBN, ES3060KBS, ES3060KBI, ES3060KBA, PM-3075KBNGT, PM-3075KBSGT, PM-3075KBIGT, PM-3075KBAGT, PM-3066KBNGT, PM-3066KBSGT, PM-3066KBIGT, PM-3066KBAGT, PM-3063KBNGT, PM-3063KBSGT, PM-3063KBIGT, PM-3063KBAGT, PM-3060KBNGT, PM-3060KBSGT, PM-3060KBIGT, PM-3060KBAGT

**Testing laboratory**

Name : Bureau Veritas Consumer Products Services (H.K.) Ltd.,  
Taoyuan Branch  
Address : No. 47-2, 14th Ling, Chia Pau Vil., Lin Kou Dist., New Taipei City, Taiwan

**Test specification**

**Standard :** IEEE 519:2014

**Test Result :** The test item passed.

**Prepared By :**

Signature

Issac Chen

Senior Engineer

2020-04-06

Date

**Approved By:**

Signature

Edward Chiueh

Technical Manager

2020-04-06

Date

**Other Aspects:**

The completed test report includes the following documents:  
IEEE 519:2014 report (42 pages)



This report is for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence, provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents. Unless specific mention, the uncertainty of measurement has been explicitly taken into account to declare the compliance or non-compliance to the specification



BUREAU  
VERITAS

## TEST REPORT

### IEEE 519:2014

#### IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

Report reference No .....	PV200319E02
Tested by (printed name and signature) .....	See cover sheet
Approved by (printed name and signature) .....	See cover sheet
Date of issue .....	See cover sheet
Testing Laboratory Name .....	Bureau Veritas Consumer Products Services (H.K.) Ltd., Taoyuan Branch
Address.....	No. 47-2, 14th Ling, Chia Pau Vil., Lin Kou Dist., New Taipei City, Taiwan
Testing location.....	Bureau Veritas Consumer Product Services Limited, Taoyuan Branch
Address.....	No.19, Hwa Ya 2nd Rd., Wen Hwa Vil., Kwei Shan Dist., Taoyuan City, Taiwan
Applicant's Name .....	ABLEREX ELECTRONICS CO., LTD.
Address .....	1F, No. 3, Lane 7, Paokao Rd., Hsintien 23144, New Taipei City, Taiwan
<b>Test specification</b>	
Standard .....	IEEE 519:2014
Non-standard test method .....	None
<b>Test Report Form No.</b> .....	IEEE 519:2014_A
Master TRF .....	Bureau Veritas Consumer Product Services GmbH
Copyright © Bureau Veritas Consumer Products Services (H.K.) Ltd., Taoyuan Branch	
<b>Test item description</b> .....	Grid-tied photovoltaic inverter
Trademark .....	
Model / Type .....	ES3075KBN, ES3075KBS, ES3075KBI, ES3075KBA, PM-3075KBNGT, PM-3075KBSGT, PM-3075KBIGT, PM-3075KBAGT
<b>Ratings</b> .....	See below
PV Array Input DC voltage range [V]:	250-1000 Vdc
PV Array Input DC current [A] .....	26 A x 4
Output AC voltage [V] .....	277/480 Vac
Output AC current [A] .....	91 A x 3
Output power [kVA] .....	75 kVA



BUREAU  
VERITAS

Model / Type .....	ES3066KBN, ES3066KBS, ES3066KBI, ES3066KBA, PM-3066KBNGT, PM-3066KBSGT, PM-3066KBIGT, PM-3066KBAGT
<b>Ratings.....</b>	See below
PV Array Input DC voltage range [V]:	250-1000 Vdc
PV Array Input DC current [A] .....	26 A x 4
Output AC voltage [V].....	277/480 Vac
Output AC current [A] .....	79.5 A x 3
Output power [kVA] .....	66 kVA
Model / Type .....	ES3063KBN, ES3063KBS, ES3063KBI, ES3063KBA, PM-3063KBNGT, PM-3063KBSGT, PM-3063KBIGT, PM-3063KBAGT
<b>Ratings.....</b>	See below
PV Array Input DC voltage range [V]:	250-1000 Vdc
PV Array Input DC current [A] .....	26 A x 4
Output AC voltage [V].....	220/380 Vac, 230/400 Vac
Output AC current [A] .....	91.3 A x 3
Output power [kVA] .....	63 kVA
Model / Type .....	ES3060KBN, ES3060KBS, ES3060KBI, ES3060KBA, PM-3060KBNGT, PM-3060KBSGT, PM-3060KBIGT, PM-3060KBAGT
<b>Ratings.....</b>	See below
PV Array Input DC voltage range [V]:	250-1000 Vdc
PV Array Input DC current [A] .....	26 A x 4
Output AC voltage [V].....	220/380 Vac, 230/400 Vac
Output AC current [A] .....	91 A x 3
Output power [kVA] .....	60 kVA



BUREAU  
VERITAS

Copy of marking plate

太陽能變流器  
型號: ES3075KBN

P/N : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率容許範圍: 200~1000 Vdc

額定交流輸出  
功率: 75 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

藍正輝順電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



V31064-B5M1

S/N : MA3C013000001

太陽能變流器  
型號: ES3075KBS

P/N : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率容許範圍: 200~1000 Vdc

額定交流輸出  
功率: 75 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

藍正輝順電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



V31064-B5M1

S/N : MA3C013000001

太陽能變流器  
型號: ES3075KBI

P/N : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率容許範圍: 200~1000 Vdc

額定交流輸出  
功率: 75 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

藍正輝順電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



V31064-B5M1

S/N : MA3C013000001

太陽能變流器  
型號: ES3075KBA

P/N : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率容許範圍: 200~1000 Vdc

額定交流輸出  
功率: 75 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

藍正輝順電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



V31064-B5M1

S/N : MA3C013000001

太陽能變流器  
型號: ES3066KBN

P/N : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率容許範圍: 200~1000 Vdc

額定交流輸出  
功率: 66 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 79.5 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

藍正輝順電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



V31064-B5M1

S/N : MA3C013000001

太陽能變流器  
型號: ES3066KBS

P/N : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率容許範圍: 200~1000 Vdc

額定交流輸出  
功率: 66 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 79.5 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

藍正輝順電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



V31064-B5M1

S/N : MA3C013000001

太陽能變流器  
型號: ES3066KBI

P/N : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率容許範圍: 200~1000 Vdc

額定交流輸出  
功率: 66 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 79.5 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

藍正輝順電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



V31064-B5M1

S/N : MA3C013000001

太陽能變流器  
型號: ES3066KBA

P/N : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率容許範圍: 200~1000 Vdc

額定交流輸出  
功率: 66 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 79.5 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

藍正輝順電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



V31064-B5M1

S/N : MA3C013000001



BUREAU  
VERITAS

**太陽能變流器**  
**型號: ES3063KBN**

P/N : XXXXXXXXX0XXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率耐受範圍: 200~1000 Vdc

額定交流輸出  
功率: 63 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91.3 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

英正匯爾電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



S/N : MA3C013000001

**太陽能變流器**  
**型號: ES3063KBS**

P/N : XXXXXXXXX0XXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率耐受範圍: 200~1000 Vdc

額定交流輸出  
功率: 63 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91.3 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

英正匯爾電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



S/N : MA3C013000001

**太陽能變流器**  
**型號: ES3063KBI**

P/N : XXXXXXXXX0XXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率耐受範圍: 200~1000 Vdc

額定交流輸出  
功率: 63 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91.3 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

英正匯爾電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



S/N : MA3C013000001

**太陽能變流器**  
**型號: ES3063KBA**

P/N : XXXXXXXXX0XXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率耐受範圍: 200~1000 Vdc

額定交流輸出  
功率: 63 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91.3 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

英正匯爾電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



S/N : MA3C013000001

**太陽能變流器**  
**型號: ES3060KBN**

P/N : XXXXXXXXX0XXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率耐受範圍: 200~1000 Vdc

額定交流輸出  
功率: 60 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

英正匯爾電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



S/N : MA3C013000001

**太陽能變流器**  
**型號: ES3060KBS**

P/N : XXXXXXXXX0XXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率耐受範圍: 200~1000 Vdc

額定交流輸出  
功率: 60 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

英正匯爾電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



S/N : MA3C013000001

**太陽能變流器**  
**型號: ES3060KBI**

P/N : XXXXXXXXX0XXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率耐受範圍: 200~1000 Vdc

額定交流輸出  
功率: 60 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

英正匯爾電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



S/N : MA3C013000001

**太陽能變流器**  
**型號: ES3060KBA**

P/N : XXXXXXXXX0XXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率耐受範圍: 200~1000 Vdc

額定交流輸出  
功率: 60 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66

英正匯爾電子股份有限公司  
ABLEREX ELECTRONICS CO., LTD.



S/N : MA3C013000001



BUREAU  
VERITAS

太陽能變流器  
型號: PM-3075KBNGT

PIN : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率逆變範圍: 200~1000 Vdc

額定交流輸出  
功率: 75 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3075KBSGT

PIN : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率逆變範圍: 200~1000 Vdc

額定交流輸出  
功率: 75 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3075KBIGT

PIN : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率逆變範圍: 200~1000 Vdc

額定交流輸出  
功率: 75 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3075KBAGT

PIN : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率逆變範圍: 200~1000 Vdc

額定交流輸出  
功率: 75 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3066KBNGT

PIN : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率逆變範圍: 200~1000 Vdc

額定交流輸出  
功率: 66 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 79.5 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3066KBSGT

PIN : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率逆變範圍: 200~1000 Vdc

額定交流輸出  
功率: 66 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 79.5 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3066KBIGT

PIN : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率逆變範圍: 200~1000 Vdc

額定交流輸出  
功率: 66 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 79.5 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3066KBAGT

PIN : XXXXXXXXXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率逆變範圍: 200~1000 Vdc

額定交流輸出  
功率: 66 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 480 Vac  
電流: 79.5 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001



BUREAU  
VERITAS

太陽能變流器  
型號: PM-3063KBNGT

P/N : XXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率追蹤範圍: 200~1000 Vdc

額定交流輸出  
功率: 63 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91.3 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3063KBSGT

P/N : XXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率追蹤範圍: 200~1000 Vdc

額定交流輸出  
功率: 63 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91.3 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3063KBIGT

P/N : XXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率追蹤範圍: 200~1000 Vdc

額定交流輸出  
功率: 63 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91.3 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3063KBAGT

P/N : XXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率追蹤範圍: 200~1000 Vdc

額定交流輸出  
功率: 63 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91.3 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3060KBNGT

P/N : XXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率追蹤範圍: 200~1000 Vdc

額定交流輸出  
功率: 60 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3060KBSGT

P/N : XXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率追蹤範圍: 200~1000 Vdc

額定交流輸出  
功率: 60 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3060KBIGT

P/N : XXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率追蹤範圍: 200~1000 Vdc

額定交流輸出  
功率: 60 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

太陽能變流器  
型號: PM-3060KBAGT

P/N : XXXXXXXXX

直流輸入  
電壓: 200~1000 Vdc  
電流: 26 Amp x 4  
最大功率追蹤範圍: 200~1000 Vdc

額定交流輸出  
功率: 60 kVA  
功率因數: 0.8超前~0.8落後  
電壓: 380 / 400 Vac  
電流: 91 Amp x 3  
頻率: 60 Hz

保護等級: I  
侵入保護: IP66



S/N : MA3C013000001

**History Sheet:**

Name	Date	Comment	Revision
Issac Chen	2020-04-06	Initial report was written	Empty

Address of the manufacturer sites:

**1) Ablerex Electronics (SUZHOU) Co., Ltd.**

No. 36 Wang Wu Road, Wu Zhong District Suzhou, 215128, P.R. China

**2) Ablerex Electronics Co., Ltd.**

No. 1-1, Gongye Rd., Pingtung City, Pingtung Country 90049, Taiwan



BUREAU  
VERITAS

<b>Particulars:</b>	
Equipment mobility .....	Permanent connection
Operating condition .....	Continuous
Class of equipment .....	Class I
<b>Test case verdicts:</b>	
Test case does not apply to the test object .....	<b>N/A</b>
Test item does meet the requirement .....	<b>P(ass)</b>
Test item does not meet the requirement .....	<b>F(ail)</b>
<b>Testing:</b>	
Date of receipt of test item .....	2020-03-19
Date(s) of performance of test .....	2020-03-24

**General remarks:**

The test result presented in this report relate only to the object(s) tested.

This report shall not be reproduced, except in full, without the written approval of the applicant.

Throughout this report a point is used as the decimal separator.

**Model Differences:**

All models are identical in software except power derating by software settings.

All models are identical in hardware except following descriptions:

Model	Description
ES3075KBN, PM-3075KBNGT	Standard Model
ES3075KBS, PM-3075KBSGT	SPD installed
ES3075KBI, PM-3075KBIGT	Smart Cloud Module installed
ES3075KBA, PM-3075KBAGT	SPD & Smart Cloud Module installed

Model	Description
ES3066KBN, PM-3066KBNGT	Standard Model
ES3066KBS, PM-3066KBSGT	SPD installed
ES3066KBI, PM-3066KBIGT	Smart Cloud Module installed
ES3066KBA, PM-3066KBAGT	SPD & Smart Cloud Module installed

Model	Description
ES3063KBN, PM-3063KBNGT	Standard Model
ES3063KBS, PM-3063KBSGT	SPD installed
ES3063KBI, PM-3063KBIGT	Smart Cloud Module installed
ES3063KBA, PM-3063KBAGT	SPD & Smart Cloud Module installed



BUREAU  
VERITAS

Model	Description
ES3060KBN, PM-3060KBNGT	Standard Model
ES3060KBS, PM-3060KBSGT	SPD installed
ES3060KBI, PM-3060KBIGT	Smart Cloud Module installed
ES3060KBA, PM-3060KBAGT	SPD & Smart Cloud Module installed

Model	Brand
ES3075KBN, ES3075KBS, ES3075KBI, ES3075KBA ES3066KBN, ES3066KBS, ES3066KBI, ES3066KBA, ES3063KBN, ES3063KBS, ES3063KBI, ES3063KBA, ES3060KBN, ES3060KBS, ES3060KBI, ES3060KBA,	
PM-3075KBNGT, PM-3075KBSGT, PM-3075KBIGT, PM-3075KBAGT, PM-3066KBNGT, PM-3066KBSGT, PM-3066KBIGT, PM-3066KBAGT, PM-3063KBNGT, PM-3063KBSGT, PM-3063KBIGT, PM-3063KBAGT, PM-3060KBNGT, PM-3060KBSGT, PM-3060KBIGT, PM-3060KBAGT	

**This Test Report consists of the following documents:**

1. Test Results
2. Annex 1:Pictures of the unit
3. Annex 2:Test equipment list



BUREAU  
VERITAS

**4.5 (B1) Harmonic Current Limit Test**

**P**

**Test Sample: ES3075KBN**

			R	S	T		
Watts [kW]			25.45	25.29	25.50		
VA [kVA]			25.48	25.34	25.53		
Vrms [V]			277.95	277.71	277.80		
Arms [A]			91.68	91.15	91.88		
Power Factor			0.9989	0.9993	0.9993		
THD [%]			3.21	2.98	3.03		
Harmonics	Current Magnitude (A)			% of Fundamental			
	R	S	T	R	S	T	Harmonic Current Limits (%)
1st	91.68	91.15	91.88	100	100	100	--
2nd	0.24	0.24	0.18	0.26	0.26	0.2	1
3rd	0.27	0.22	0.29	0.30	0.24	0.32	4
4th	0.29	0.21	0.23	0.32	0.23	0.25	1
5th	2.28	2.14	2.02	2.51	2.35	2.22	4
6th	0.21	0.08	0.18	0.23	0.09	0.20	1
7th	1.73	1.53	1.67	1.90	1.68	1.84	4
8th	0.15	0.11	0.06	0.16	0.12	0.07	1
9th	0.09	0.08	0.09	0.10	0.09	0.10	4
10th	0.10	0.05	0.10	0.11	0.05	0.11	1
11th	0.64	0.70	0.57	0.70	0.77	0.63	2
12th	0.05	0.04	0.06	0.06	0.04	0.07	0.5
13th	0.45	0.44	0.50	0.49	0.48	0.55	2
14th	0.03	0.03	0.04	0.03	0.03	0.04	0.5
15th	0.04	0.04	0.05	0.04	0.04	0.05	2
16th	0.04	0.04	0.05	0.04	0.04	0.05	0.5
17th	0.25	0.30	0.26	0.28	0.33	0.29	1.5
18th	0.02	0.03	0.03	0.02	0.03	0.03	0.375
19th	0.22	0.22	0.25	0.24	0.24	0.27	1.5
20th	0.03	0.04	0.04	0.03	0.04	0.04	0.375
21th	0.04	0.05	0.05	0.04	0.05	0.05	1.5
22th	0.05	0.12	0.08	0.05	0.13	0.09	0.375
23th	0.14	0.17	0.16	0.15	0.19	0.18	0.6
24th	0.02	0.03	0.02	0.02	0.03	0.02	0.15
25th	0.12	0.13	0.14	0.13	0.14	0.15	0.6
26th	0.03	0.03	0.03	0.03	0.03	0.03	0.15
27th	0.02	0.03	0.03	0.02	0.03	0.03	0.6
28th	0.03	0.03	0.03	0.03	0.03	0.03	0.15
29th	0.09	0.11	0.11	0.10	0.12	0.12	0.6
30th	0.01	0.02	0.02	0.01	0.02	0.02	0.15
31th	0.08	0.09	0.09	0.09	0.10	0.10	0.6
32th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
33th	0.02	0.02	0.02	0.02	0.02	0.02	0.6
34th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
35th	0.06	0.08	0.07	0.07	0.09	0.08	0.3
36th	0.01	0.01	0.01	0.01	0.01	0.01	0.075



BUREAU  
VERITAS

**Test Sample: ES3075KBN**

			R	S	T		
Watts [kW]			25.45	25.29	25.50		
VA [kVA]			25.48	25.34	25.53		
Vrms [V]			277.95	277.71	277.80		
Arms [A]			91.68	91.15	91.88		
Power Factor			0.9989	0.9993	0.9993		
THD [%]			3.21	2.98	3.03		
Harmonics	Current Magnitude (A)			% of Fundamental		Harmonic Current Limit (%)	
	R	S	T	R	S	T	
37th	0.06	0.07	0.06	0.07	0.08	0.07	0.3
38th	0.02	0.03	0.02	0.02	0.03	0.02	0.075
39th	0.02	0.02	0.02	0.02	0.02	0.02	0.3
40th	0.02	0.03	0.02	0.02	0.03	0.02	0.075
41th	0.04	0.05	0.05	0.04	0.05	0.05	0.3
42th	0.01	0.02	0.01	0.01	0.02	0.01	0.075
43th	0.05	0.05	0.05	0.06	0.06	0.06	0.3
44th	0.03	0.03	0.02	0.03	0.03	0.02	0.075
45th	0.05	0.04	0.02	0.05	0.04	0.02	0.3
46th	0.02	0.02	0.02	0.02	0.02	0.02	0.075
47th	0.06	0.05	0.06	0.07	0.05	0.07	0.3
48th	0.03	0.02	0.02	0.03	0.02	0.02	0.075
49th	0.03	0.02	0.02	0.03	0.02	0.02	0.3
50th	0.02	0.01	0.01	0.02	0.01	0.01	0.075
<b>Note:</b> ISC/IL = 20 Ref. to Table 2 of the IEEE 519:2014							

BUREAU  
VERITAS

Test Sample: ES3066KBN							
			R	S	T		
<b>Watts [kW]</b>			22.35	22.14	22.34		
<b>VA [kVA]</b>			22.38	22.17	22.35		
<b>Vrms [V]</b>			277.69	277.57	277.63		
<b>Arms [A]</b>			80.57	79.82	80.54		
<b>Power Factor</b>			0.9990	0.9992	0.9992		
<b>THD [%]</b>			3.35	2.93	3.52		
Harmonics	<b>Current Magnitude (A)</b>			<b>% of Fundamental</b>			
	R	S	T	R	S	T	
1st	80.57	79.82	80.54	100	100	100	--
2nd	0.25	0.30	0.15	0.31	0.38	0.19	1
3rd	0.58	0.82	0.41	0.73	1.03	0.52	4
4th	0.28	0.26	0.23	0.35	0.33	0.29	1
5th	2.11	1.41	1.78	2.66	1.77	2.24	4
6th	0.18	0.14	0.21	0.23	0.17	0.27	1
7th	1.49	1.72	2.08	1.88	2.16	2.62	4
8th	0.14	0.12	0.10	0.18	0.15	0.12	1
9th	0.31	0.45	0.23	0.39	0.56	0.29	4
10th	0.10	0.08	0.10	0.12	0.10	0.13	1
11th	0.45	0.48	0.59	0.57	0.60	0.74	2
12th	0.07	0.07	0.09	0.09	0.09	0.11	0.5
13th	0.29	0.38	0.52	0.37	0.48	0.65	2
14th	0.05	0.04	0.04	0.06	0.05	0.05	0.5
15th	0.16	0.12	0.12	0.20	0.15	0.15	2
16th	0.05	0.04	0.06	0.06	0.05	0.07	0.5
17th	0.29	0.33	0.29	0.36	0.41	0.37	1.5
18th	0.04	0.03	0.05	0.05	0.04	0.06	0.375
19th	0.15	0.12	0.18	0.19	0.15	0.23	1.5
20th	0.02	0.02	0.03	0.03	0.03	0.04	0.375
21th	0.09	0.05	0.10	0.11	0.06	0.12	1.5
22th	0.04	0.10	0.07	0.05	0.13	0.09	0.375
23th	0.15	0.17	0.14	0.19	0.22	0.17	0.6
24th	0.02	0.03	0.03	0.03	0.04	0.04	0.15
25th	0.10	0.11	0.14	0.12	0.14	0.17	0.6
26th	0.02	0.02	0.02	0.03	0.03	0.03	0.15
27th	0.04	0.04	0.06	0.05	0.05	0.08	0.6
28th	0.02	0.02	0.02	0.03	0.03	0.03	0.15
29th	0.08	0.09	0.07	0.10	0.11	0.09	0.6
30th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
31th	0.06	0.06	0.10	0.08	0.08	0.12	0.6
32th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
33th	0.03	0.02	0.03	0.04	0.03	0.04	0.6
34th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
35th	0.04	0.05	0.04	0.05	0.06	0.05	0.3
36th	0.02	0.02	0.02	0.02	0.02	0.02	0.075
37th	0.05	0.03	0.05	0.06	0.04	0.06	0.3
38th	0.02	0.02	0.02	0.02	0.03	0.03	0.075
39th	0.02	0.02	0.02	0.03	0.02	0.03	0.3
40th	0.02	0.02	0.02	0.02	0.02	0.03	0.075



BUREAU  
VERITAS

**Test Sample: ES3066KBN**

			R	S	T		
<b>Watts [kW]</b>			22.35	22.14	22.34		
<b>VA [kVA]</b>			22.38	22.17	22.35		
<b>Vrms [V]</b>			277.69	277.57	277.63		
<b>Arms [A]</b>			80.57	79.82	80.54		
<b>Power Factor</b>			0.9990	0.9992	0.9992		
<b>THD [%]</b>			3.35	2.93	3.52		
Harmonics	<b>Current Magnitude (A)</b>			<b>% of Fundamental</b>		Harmonic Current Limits (%)	
	R	S	T	R	S	T	
41th	0.04	0.05	0.02	0.05	0.06	0.03	0.3
42th	0.02	0.02	0.02	0.02	0.02	0.02	0.075
43th	0.05	0.04	0.04	0.06	0.05	0.05	0.3
44th	0.02	0.02	0.02	0.03	0.02	0.03	0.075
45th	0.06	0.03	0.03	0.07	0.04	0.04	0.3
46th	0.02	0.02	0.02	0.02	0.02	0.02	0.075
47th	0.02	0.02	0.02	0.03	0.03	0.03	0.3
48th	0.02	0.02	0.02	0.02	0.02	0.02	0.075
49th	0.02	0.02	0.02	0.02	0.03	0.02	0.3
50th	0.02	0.02	0.01	0.02	0.02	0.01	0.075

**Note:**

ISC/IL = 20

Ref. to Table 2 of the IEEE 519:2014



BUREAU  
VERITAS

Test Sample: ES3063KBN							
			R	S	T		
<b>Watts [kW]</b>			21.36	21.25	21.45		
<b>VA [kVA]</b>			21.41	21.28	21.49		
<b>Vrms [V]</b>			230.92	230.80	230.87		
<b>Arms [A]</b>			92.62	92.15	92.96		
<b>Power Factor</b>			0.9990	0.9993	0.9993		
<b>THD [%]</b>			3.06	2.92	2.90		
Harmonics	<b>Current Magnitude (A)</b>			<b>% of Fundamental</b>			
	R	S	T	R	S	T	
1st	92.62	92.15	92.96	100	100	100	--
2nd	0.16	0.23	0.16	0.17	0.25	0.17	1
3rd	0.24	0.26	0.37	0.26	0.28	0.41	4
4th	0.23	0.16	0.16	0.25	0.17	0.18	1
5th	2.18	2.08	1.94	2.39	2.28	2.12	4
6th	0.19	0.08	0.18	0.21	0.09	0.2	1
7th	1.59	1.46	1.63	1.74	1.6	1.78	4
8th	0.14	0.11	0.06	0.15	0.12	0.07	1
9th	0.12	0.09	0.11	0.13	0.10	0.12	4
10th	0.10	0.05	0.10	0.11	0.05	0.11	1
11th	0.58	0.66	0.55	0.64	0.72	0.6	2
12th	0.05	0.04	0.05	0.05	0.04	0.06	0.5
13th	0.39	0.37	0.45	0.43	0.41	0.49	2
14th	0.03	0.03	0.04	0.03	0.03	0.04	0.5
15th	0.04	0.05	0.05	0.04	0.05	0.05	2
16th	0.03	0.03	0.04	0.03	0.03	0.04	0.5
17th	0.22	0.26	0.24	0.24	0.28	0.26	1.5
18th	0.02	0.03	0.03	0.02	0.03	0.03	0.375
19th	0.18	0.18	0.20	0.2	0.2	0.22	1.5
20th	0.02	0.03	0.03	0.02	0.03	0.03	0.375
21th	0.03	0.05	0.04	0.03	0.05	0.04	1.5
22th	0.05	0.12	0.07	0.05	0.13	0.08	0.375
23th	0.13	0.16	0.15	0.14	0.17	0.16	0.6
24th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
25th	0.12	0.11	0.12	0.13	0.12	0.13	0.6
26th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
27th	0.02	0.02	0.03	0.02	0.02	0.03	0.6
28th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
29th	0.07	0.10	0.09	0.08	0.11	0.1	0.6
30th	0.01	0.02	0.02	0.01	0.02	0.02	0.15
31th	0.07	0.08	0.08	0.08	0.09	0.09	0.6
32th	0.01	0.02	0.02	0.01	0.02	0.02	0.15
33th	0.02	0.02	0.02	0.02	0.02	0.02	0.6
34th	0.01	0.02	0.02	0.01	0.02	0.02	0.15
35th	0.06	0.06	0.06	0.07	0.07	0.07	0.3
36th	0.01	0.01	0.01	0.01	0.01	0.01	0.075
37th	0.05	0.05	0.06	0.06	0.06	0.07	0.3
38th	0.02	0.02	0.02	0.02	0.02	0.02	0.075
39th	0.01	0.02	0.02	0.01	0.02	0.02	0.3
40th	0.02	0.02	0.02	0.02	0.02	0.02	0.075



BUREAU  
VERITAS

**Test Sample: ES3063KBN**

			R	S	T		
<b>Watts [kW]</b>			21.36	21.25	21.45		
<b>VA [kVA]</b>			21.41	21.28	21.49		
<b>Vrms [V]</b>			230.92	230.80	230.87		
<b>Arms [A]</b>			92.62	92.15	92.96		
<b>Power Factor</b>			0.9990	0.9993	0.9993		
<b>THD [%]</b>			3.06	2.92	2.90		
Harmonics	<b>Current Magnitude (A)</b>			<b>% of Fundamental</b>		Harmonic Current Limits (%)	
	R	S	T	R	S	T	
41th	0.04	0.05	0.05	0.04	0.05	0.05	0.3
42th	0.01	0.01	0.01	0.01	0.01	0.01	0.075
43th	0.05	0.06	0.05	0.06	0.07	0.06	0.3
44th	0.02	0.02	0.02	0.02	0.02	0.02	0.075
45th	0.05	0.04	0.03	0.06	0.04	0.03	0.3
46th	0.01	0.01	0.01	0.01	0.01	0.01	0.075
47th	0.07	0.05	0.07	0.08	0.06	0.08	0.3
48th	0.02	0.01	0.01	0.02	0.01	0.01	0.075
49th	0.02	0.03	0.03	0.02	0.03	0.03	0.3
50th	0.01	0.01	0.01	0.01	0.01	0.01	0.075

**Note:**

ISC/IL = 20

Ref. to Table 2 of the IEEE 519:2014

BUREAU  
VERITAS

Test Sample: ES3060KBN							
			R	S	T		
<b>Watts [kW]</b>			20.26	20.18	20.30		
<b>VA [kVA]</b>			20.32	20.20	20.37		
<b>Vrms [V]</b>			220.92	220.81	220.88		
<b>Arms [A]</b>			91.78	91.45	91.97		
<b>Power Factor</b>			0.9990	0.9992	0.9992		
<b>THD [%]</b>			3.11	2.89	2.89		
Harmonics	<b>Current Magnitude (A)</b>			<b>% of Fundamental</b>			
	R	S	T	R	S	T	
1st	91.78	91.45	91.97	100	100	100	--
2nd	0.20	0.23	0.16	0.22	0.25	0.18	1
3rd	0.20	0.21	0.28	0.22	0.23	0.31	4
4th	0.24	0.18	0.18	0.26	0.2	0.2	1
5th	2.27	2.09	1.99	2.49	2.3	2.19	4
6th	0.18	0.06	0.17	0.2	0.07	0.19	1
7th	1.56	1.40	1.56	1.71	1.54	1.71	4
8th	0.13	0.10	0.06	0.14	0.11	0.07	1
9th	0.10	0.06	0.10	0.11	0.07	0.11	4
10th	0.08	0.05	0.07	0.09	0.05	0.08	1
11th	0.56	0.61	0.55	0.62	0.67	0.6	2
12th	0.05	0.04	0.05	0.05	0.04	0.06	0.5
13th	0.37	0.36	0.41	0.41	0.4	0.45	2
14th	0.03	0.03	0.03	0.03	0.03	0.03	0.5
15th	0.03	0.04	0.04	0.03	0.04	0.04	2
16th	0.03	0.03	0.04	0.03	0.03	0.04	0.5
17th	0.22	0.24	0.23	0.24	0.26	0.25	1.5
18th	0.02	0.02	0.03	0.02	0.02	0.03	0.375
19th	0.17	0.17	0.18	0.19	0.19	0.2	1.5
20th	0.02	0.03	0.03	0.02	0.03	0.03	0.375
21th	0.03	0.05	0.04	0.03	0.05	0.04	1.5
22th	0.05	0.11	0.07	0.05	0.12	0.08	0.375
23th	0.12	0.15	0.14	0.13	0.16	0.15	0.6
24th	0.02	0.03	0.02	0.02	0.03	0.02	0.15
25th	0.11	0.11	0.12	0.12	0.12	0.13	0.6
26th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
27th	0.02	0.02	0.02	0.02	0.02	0.02	0.6
28th	0.02	0.02	0.02	0.02	0.02	0.02	0.15
29th	0.07	0.09	0.09	0.08	0.1	0.1	0.6
30th	0.01	0.01	0.02	0.01	0.01	0.02	0.15
31th	0.07	0.07	0.07	0.08	0.08	0.08	0.6
32th	0.01	0.02	0.02	0.01	0.02	0.02	0.15
33th	0.01	0.02	0.02	0.01	0.02	0.02	0.6
34th	0.01	0.02	0.02	0.01	0.02	0.02	0.15
35th	0.05	0.06	0.06	0.06	0.07	0.07	0.3
36th	0.01	0.01	0.01	0.01	0.01	0.01	0.075
37th	0.05	0.05	0.06	0.06	0.06	0.07	0.3
38th	0.01	0.02	0.02	0.01	0.02	0.02	0.075
39th	0.02	0.02	0.02	0.02	0.02	0.02	0.3
40th	0.02	0.02	0.02	0.02	0.02	0.02	0.075



BUREAU  
VERITAS

**Test Sample: ES3060KBN**

			R	S	T		
<b>Watts [kW]</b>			20.26	20.18	20.30		
<b>VA [kVA]</b>			20.32	20.20	20.37		
<b>Vrms [V]</b>			220.92	220.81	220.88		
<b>Arms [A]</b>			91.78	91.45	91.97		
<b>Power Factor</b>			0.9990	0.9992	0.9992		
<b>THD [%]</b>			3.11	2.89	2.89		
Harmonics	<b>Current Magnitude (A)</b>			<b>% of Fundamental</b>		Harmonic Current Limits (%)	
	R	S	T	R	S	T	
41th	0.05	0.05	0.05	0.05	0.05	0.05	0.3
42th	0.01	0.02	0.01	0.01	0.02	0.01	0.075
43th	0.05	0.06	0.05	0.06	0.07	0.06	0.3
44th	0.02	0.02	0.02	0.02	0.02	0.02	0.075
45th	0.06	0.04	0.04	0.07	0.04	0.04	0.3
46th	0.01	0.01	0.02	0.01	0.01	0.02	0.075
47th	0.06	0.05	0.06	0.07	0.05	0.07	0.3
48th	0.01	0.01	0.01	0.01	0.01	0.01	0.075
49th	0.03	0.03	0.03	0.03	0.03	0.03	0.3
50th	0.01	0.01	0.01	0.01	0.01	0.01	0.075

**Note:**

ISC/IL = 20

Ref. to Table 2 of the IEEE 519:2014



BUREAU  
VERITAS

4.5 (B1) Harmonic Voltage Limit Test						P	
Test Sample: ES3075KBN							
THD50 (%)	R	0.95	S	0.87	T	0.88	
Harmonics	Voltage Magnitude (V)			% of Fundamental			
	R	S	T	R	S	T	
1st	277.85	277.71	277.80	100	100	100	--
2nd	0.08	0.08	0.06	0.03	0.03	0.02	3
3rd	0.86	0.80	0.66	0.31	0.29	0.24	3
4th	0.17	0.11	0.14	0.06	0.04	0.05	3
5th	1.33	1.25	1.19	0.48	0.45	0.43	3
6th	0.17	0.06	0.17	0.06	0.02	0.06	3
7th	1.69	1.50	1.63	0.61	0.54	0.59	3
8th	0.17	0.14	0.06	0.06	0.05	0.02	3
9th	0.33	0.22	0.25	0.12	0.08	0.09	3
10th	0.14	0.08	0.11	0.05	0.03	0.04	3
11th	0.97	1.02	0.89	0.35	0.37	0.32	3
12th	0.08	0.06	0.08	0.03	0.02	0.03	3
13th	0.72	0.69	0.78	0.26	0.25	0.28	3
14th	0.06	0.06	0.06	0.02	0.02	0.02	3
15th	0.22	0.19	0.17	0.08	0.07	0.06	3
16th	0.06	0.06	0.06	0.02	0.02	0.02	3
17th	0.39	0.44	0.42	0.14	0.16	0.15	3
18th	0.03	0.03	0.03	0.01	0.01	0.01	3
19th	0.30	0.33	0.36	0.11	0.12	0.13	3
20th	0.03	0.06	0.06	0.01	0.02	0.02	3
21th	0.06	0.08	0.08	0.02	0.03	0.03	3
22th	0.06	0.17	0.11	0.02	0.06	0.04	3
23th	0.25	0.28	0.25	0.09	0.1	0.09	3
24th	0.03	0.03	0.03	0.01	0.01	0.01	3
25th	0.19	0.19	0.22	0.07	0.07	0.08	3
26th	0.03	0.03	0.03	0.01	0.01	0.01	3
27th	0.06	0.06	0.06	0.02	0.02	0.02	3
28th	0.03	0.03	0.06	0.01	0.01	0.02	3
29th	0.14	0.17	0.17	0.05	0.06	0.06	3
30th	0.03	0.03	0.03	0.01	0.01	0.01	3
31th	0.11	0.14	0.14	0.04	0.05	0.05	3
32th	0.03	0.03	0.03	0.01	0.01	0.01	3
33th	0.03	0.03	0.03	0.01	0.01	0.01	3
34th	0.03	0.03	0.03	0.01	0.01	0.01	3
35th	0.11	0.14	0.14	0.04	0.05	0.05	3
36th	0.03	0.03	0.03	0.01	0.01	0.01	3
37th	0.11	0.14	0.14	0.04	0.05	0.05	3
38th	0.06	0.08	0.08	0.02	0.03	0.03	3
39th	0.03	0.06	0.06	0.01	0.02	0.02	3
40th	0.08	0.08	0.06	0.03	0.03	0.02	3
41th	0.08	0.11	0.11	0.03	0.04	0.04	3
42th	0.03	0.03	0.03	0.01	0.01	0.01	3



BUREAU  
VERITAS

**Test Sample: ES3075KBN**

THD50 (%)		R	0.95	S	0.87	T	0.88
Harmonics	Voltage Magnitude (V)			% of Fundamental			Harmonic Limits of Test Voltage (%)
	R	S	T	R	S	T	
43th	0.14	0.14	0.14	0.05	0.05	0.05	3
44th	0.06	0.06	0.06	0.02	0.02	0.02	3
45th	0.11	0.11	0.08	0.04	0.04	0.03	3
46th	0.06	0.06	0.06	0.02	0.02	0.02	3
47th	0.17	0.11	0.17	0.06	0.04	0.06	3
48th	0.08	0.06	0.06	0.03	0.02	0.02	3
49th	0.08	0.06	0.06	0.03	0.02	0.02	3
50th	0.06	0.03	0.03	0.02	0.01	0.01	3

**Note:**



BUREAU  
VERITAS

Test Sample: ES3066KBN							
THD50 (%)	R	0.87	S	0.82	T	0.98	
Harmonics	Voltage Magnitude (V)			% of Fundamental			Harmonic Limits of Test Voltage (%)
	R	S	T	R	S	T	
1st	277.69	277.57	277.63	100	100	100	--
2nd	0.08	0.11	0.06	0.03	0.04	0.02	3
3rd	0.86	0.69	0.61	0.31	0.25	0.22	3
4th	0.17	0.17	0.17	0.06	0.06	0.06	3
5th	1.36	0.89	1.16	0.49	0.32	0.42	3
6th	0.17	0.11	0.19	0.06	0.04	0.07	3
7th	1.55	1.75	2.11	0.56	0.63	0.76	3
8th	0.17	0.14	0.08	0.06	0.05	0.03	3
9th	0.11	0.75	0.30	0.04	0.27	0.11	3
10th	0.11	0.11	0.11	0.04	0.04	0.04	3
11th	0.75	0.78	0.91	0.27	0.28	0.33	3
12th	0.11	0.08	0.11	0.04	0.03	0.04	3
13th	0.44	0.47	0.69	0.16	0.17	0.25	3
14th	0.06	0.06	0.06	0.02	0.02	0.02	3
15th	0.25	0.19	0.14	0.09	0.07	0.05	3
16th	0.06	0.06	0.08	0.02	0.02	0.03	3
17th	0.39	0.44	0.42	0.14	0.16	0.15	3
18th	0.06	0.06	0.06	0.02	0.02	0.02	3
19th	0.19	0.19	0.28	0.07	0.07	0.10	3
20th	0.03	0.03	0.06	0.01	0.01	0.02	3
21th	0.11	0.08	0.14	0.04	0.03	0.05	3
22th	0.06	0.14	0.11	0.02	0.05	0.04	3
23th	0.22	0.25	0.22	0.08	0.09	0.08	3
24th	0.03	0.03	0.06	0.01	0.01	0.02	3
25th	0.14	0.17	0.22	0.05	0.06	0.08	3
26th	0.03	0.03	0.06	0.01	0.01	0.02	3
27th	0.08	0.08	0.08	0.03	0.03	0.03	3
28th	0.06	0.03	0.06	0.02	0.01	0.02	3
29th	0.11	0.14	0.11	0.04	0.05	0.04	3
30th	0.03	0.03	0.03	0.01	0.01	0.01	3
31th	0.11	0.11	0.17	0.04	0.04	0.06	3
32th	0.03	0.03	0.03	0.01	0.01	0.01	3
33th	0.06	0.08	0.06	0.02	0.03	0.02	3
34th	0.03	0.03	0.03	0.01	0.01	0.01	3
35th	0.08	0.11	0.11	0.03	0.04	0.04	3
36th	0.03	0.03	0.03	0.01	0.01	0.01	3
37th	0.11	0.08	0.11	0.04	0.03	0.04	3
38th	0.06	0.06	0.08	0.02	0.02	0.03	3
39th	0.06	0.06	0.06	0.02	0.02	0.02	3
40th	0.06	0.08	0.08	0.02	0.03	0.03	3
41th	0.08	0.08	0.08	0.03	0.03	0.03	3
42th	0.03	0.03	0.03	0.01	0.01	0.01	3
43th	0.11	0.08	0.08	0.04	0.03	0.03	3
44th	0.06	0.06	0.06	0.02	0.02	0.02	3
45th	0.14	0.08	0.08	0.05	0.03	0.03	3



BUREAU  
VERITAS

**Test Sample: ES3066KBN**

<b>THD50 (%)</b>	<b>R</b>	<b>0.87</b>	<b>S</b>	<b>0.82</b>	<b>T</b>	<b>0.98</b>
------------------	----------	-------------	----------	-------------	----------	-------------

Harmonics	Voltage Magnitude (V)			% of Fundamental			Harmonic Limits of Test Voltage (%)
	R	S	T	R	S	T	
46th	0.06	0.03	0.06	0.02	0.01	0.02	3
47th	0.08	0.06	0.06	0.03	0.02	0.02	3
48th	0.06	0.03	0.03	0.02	0.01	0.01	3
49th	0.06	0.06	0.06	0.02	0.02	0.02	3
50th	0.06	0.03	0.03	0.02	0.01	0.01	3

**Note:**



BUREAU  
VERITAS

Test Sample: ES3063KBN							
THD50 (%)	R	1.07	S	1.02	T	1.02	
Harmonics	Voltage Magnitude (V)			% of Fundamental			Harmonic Limits of Test Voltage (%)
	R	S	T	R	S	T	
1st	230.92	230.80	230.87	100	100	100	--
2nd	0.07	0.09	0.07	0.03	0.04	0.03	3
3rd	0.94	0.90	0.74	0.41	0.39	0.32	3
4th	0.14	0.07	0.12	0.06	0.03	0.05	3
5th	1.27	1.20	1.13	0.55	0.52	0.49	3
6th	0.16	0.07	0.16	0.07	0.03	0.07	3
7th	1.47	1.33	1.50	0.64	0.58	0.65	3
8th	0.16	0.14	0.07	0.07	0.06	0.03	3
9th	0.25	0.12	0.14	0.11	0.05	0.06	3
10th	0.14	0.07	0.09	0.06	0.03	0.04	3
11th	0.85	0.92	0.78	0.37	0.40	0.34	3
12th	0.07	0.05	0.07	0.03	0.02	0.03	3
13th	0.67	0.64	0.71	0.29	0.28	0.31	3
14th	0.05	0.05	0.05	0.02	0.02	0.02	3
15th	0.23	0.23	0.18	0.10	0.10	0.08	3
16th	0.05	0.05	0.05	0.02	0.02	0.02	3
17th	0.37	0.41	0.41	0.16	0.18	0.18	3
18th	0.02	0.02	0.05	0.01	0.01	0.02	3
19th	0.30	0.28	0.32	0.13	0.12	0.14	3
20th	0.02	0.05	0.05	0.01	0.02	0.02	3
21th	0.07	0.07	0.07	0.03	0.03	0.03	3
22th	0.07	0.16	0.12	0.03	0.07	0.05	3
23th	0.21	0.25	0.23	0.09	0.11	0.1	3
24th	0.02	0.02	0.02	0.01	0.01	0.01	3
25th	0.21	0.18	0.21	0.09	0.08	0.09	3
26th	0.02	0.02	0.02	0.01	0.01	0.01	3
27th	0.05	0.05	0.07	0.02	0.02	0.03	3
28th	0.02	0.02	0.02	0.01	0.01	0.01	3
29th	0.14	0.18	0.16	0.06	0.08	0.07	3
30th	0.02	0.02	0.02	0.01	0.01	0.01	3
31th	0.14	0.14	0.14	0.06	0.06	0.06	3
32th	0.02	0.02	0.02	0.01	0.01	0.01	3
33th	0.05	0.05	0.05	0.02	0.02	0.02	3
34th	0.02	0.02	0.02	0.01	0.01	0.01	3
35th	0.09	0.12	0.12	0.04	0.05	0.05	3
36th	0.02	0.02	0.02	0.01	0.01	0.01	3
37th	0.09	0.09	0.12	0.04	0.04	0.05	3
38th	0.05	0.07	0.07	0.02	0.03	0.03	3
39th	0.02	0.05	0.05	0.01	0.02	0.02	3
40th	0.07	0.07	0.07	0.03	0.03	0.03	3
41th	0.09	0.09	0.09	0.04	0.04	0.04	3
42th	0.02	0.05	0.02	0.01	0.02	0.01	3
43th	0.14	0.16	0.14	0.06	0.07	0.06	3
44th	0.05	0.05	0.05	0.02	0.02	0.02	3
45th	0.14	0.09	0.07	0.06	0.04	0.03	3



BUREAU  
VERITAS

**Test Sample: ES3063KBN**

THD50 (%)		R	1.07	S	1.02	T	1.02
Harmonics	Voltage Magnitude (V)			% of Fundamental			Harmonic Limits of Test Voltage (%)
	R	S	T	R	S	T	
46th	0.05	0.02	0.05	0.02	0.01	0.02	3
47th	0.21	0.14	0.18	0.09	0.06	0.08	3
48th	0.05	0.02	0.05	0.02	0.01	0.02	3
49th	0.05	0.05	0.05	0.02	0.02	0.02	3
50th	0.02	0.02	0.02	0.01	0.01	0.01	3

**Note:**



BUREAU  
VERITAS

Test Sample: ES3060KBN							
THD50 (%)	R	1.12	S	1.04	T	1.05	
Harmonics	Voltage Magnitude (V)			% of Fundamental			Harmonic Limits of Test Voltage (%)
	R	S	T	R	S	T	
1st	220.92	220.81	220.88	100	100	100	--
2nd	0.07	0.11	0.07	0.03	0.05	0.03	3
3rd	0.92	0.88	0.75	0.42	0.4	0.34	3
4th	0.13	0.09	0.11	0.06	0.04	0.05	3
5th	1.32	1.21	1.14	0.6	0.55	0.52	3
6th	0.15	0.07	0.15	0.07	0.03	0.07	3
7th	1.39	1.25	1.39	0.63	0.57	0.63	3
8th	0.13	0.13	0.07	0.06	0.06	0.03	3
9th	0.24	0.13	0.11	0.11	0.06	0.05	3
10th	0.11	0.07	0.07	0.05	0.03	0.03	3
11th	0.81	0.88	0.79	0.37	0.4	0.36	3
12th	0.07	0.04	0.07	0.03	0.02	0.03	3
13th	0.64	0.62	0.68	0.29	0.28	0.31	3
14th	0.04	0.04	0.04	0.02	0.02	0.02	3
15th	0.20	0.22	0.20	0.09	0.1	0.09	3
16th	0.04	0.04	0.04	0.02	0.02	0.02	3
17th	0.37	0.40	0.40	0.17	0.18	0.18	3
18th	0.02	0.04	0.04	0.01	0.02	0.02	3
19th	0.29	0.29	0.31	0.13	0.13	0.14	3
20th	0.02	0.04	0.04	0.01	0.02	0.02	3
21th	0.07	0.09	0.07	0.03	0.04	0.03	3
22th	0.07	0.15	0.09	0.03	0.07	0.04	3
23th	0.20	0.24	0.22	0.09	0.11	0.1	3
24th	0.02	0.02	0.02	0.01	0.01	0.01	3
25th	0.20	0.18	0.20	0.09	0.08	0.09	3
26th	0.02	0.02	0.02	0.01	0.01	0.01	3
27th	0.04	0.07	0.07	0.02	0.03	0.03	3
28th	0.02	0.02	0.02	0.01	0.01	0.01	3
29th	0.13	0.15	0.15	0.06	0.07	0.07	3
30th	0.02	0.02	0.02	0.01	0.01	0.01	3
31th	0.13	0.13	0.13	0.06	0.06	0.06	3
32th	0.02	0.02	0.02	0.01	0.01	0.01	3
33th	0.04	0.04	0.04	0.02	0.02	0.02	3
34th	0.02	0.02	0.02	0.01	0.01	0.01	3
35th	0.09	0.09	0.11	0.04	0.04	0.05	3
36th	0.02	0.02	0.02	0.01	0.01	0.01	3
37th	0.09	0.09	0.09	0.04	0.04	0.04	3
38th	0.04	0.07	0.07	0.02	0.03	0.03	3
39th	0.02	0.07	0.04	0.01	0.03	0.02	3
40th	0.07	0.07	0.07	0.03	0.03	0.03	3
41th	0.09	0.09	0.09	0.04	0.04	0.04	3
42th	0.02	0.04	0.04	0.01	0.02	0.02	3
43th	0.13	0.15	0.13	0.06	0.07	0.06	3
44th	0.04	0.04	0.04	0.02	0.02	0.02	3
45th	0.18	0.09	0.07	0.08	0.04	0.03	3
46th	0.04	0.02	0.04	0.02	0.01	0.02	3



BUREAU  
VERITAS

**Test Sample: ES3060KBN**

THD50 (%)		R	1.12	S	1.04	T	1.05
Harmonics	Voltage Magnitude (V)			% of Fundamental			Harmonic Limits of Test Voltage (%)
	R	S	T	R	S	T	
47th	0.18	0.13	0.18	0.08	0.06	0.08	3
48th	0.04	0.02	0.04	0.02	0.01	0.02	3
49th	0.04	0.07	0.07	0.02	0.03	0.03	3
50th	0.02	0.04	0.02	0.01	0.02	0.01	3

**Note:**



## **Annex 1**

### **Pictures of the unit**

**Inverter  
Enclosure front**



**Enclosure rear side**





BUREAU  
VERITAS

**Enclosure Left side**



**Enclosure right side**





**Enclosure top side**



**Enclosure bottom side**






**Internal view-1****Internal view-2**



### PCB\_PVLF4 component side



### PCB\_PVLF4 solder side



**PCB\_PVLF5 component side****PCB\_PVLF5 solder side**

**PCB\_PVLP4 component side****PCB\_PVLP4 solder side**




BUREAU  
VERITAS

**PCB\_PVLD4 component side**




**PCB\_PVLD4 solder side**







BUREAU  
VERITAS



**PCB\_PVLD7 component side**



**PCB\_PVLD7 solder side**



**PCB\_PVLP2 component side****PCB\_PVLP2 solder side**

**PCB\_PVLP1 component side****PCB\_PVLP1 solder side**

**PCB\_PVLF30 component side**



**PCB\_PVLF30 solder side**





## **Annex 2**

### **Test equipment list**



BUREAU  
VERITAS

<b>Testing Location:</b>	Bureau Veritas Consumer Products Services (H.K.) Ltd., Taoyuan Branch			
<b>Date(s) of performance test:</b>	2020-03-24			

Equipment	Manufacturer	Type	Serial No.	Last Calibration
Thermo-Hygro Meter	--	TH-05A	245	2019-05-07
Precision Power Analyzer	HIOKI	3390	100822876	2019-05-08
Current Transducer	HIOKI	6863	130302926	Combine calibration with HIOKI 3390
Current Transducer	HIOKI	6863	130302925	
Current Transducer	HIOKI	6863	130302927	
Programable DC Source	CHROMA	62150H-1000S	62150EF00074	Monitor by Power Analyzer
Programable DC Source	CHROMA	A620028	620028E00603	
Programable DC Source	CHROMA	62150H-1000S	62150EF01542	
Programable DC Source	CHROMA	A620028	620028E00591	
Programable DC Source	CHROMA	62150H-1000S	62150EF00865	
Programable DC Source	CHROMA	A620028	620028E00713	
Programable DC Source	CHROMA	62150H-1000S	62150EF00082	
Programable DC Source	CHROMA	A620028	620028E00707	
Programable AC Source	CHROMA	61860	618603800187	Monitor by Power Analyzer
Atmospheric pressure gauge	TESTO	TESTO 511	39108378	2019-06-05